



Office Of The Civil Surgeon Rohtak


No:AUO H.B./2020/ 134

Dated: 18/06/2020

This is to certified that the premises of Vidya Shree Internationals School. ROHTAK have been visited. There is adequate space &. Rooms in school . The Rooms of the school are ventilated. All the Room & vicinity are neat and clean. There is adequate facility of drinking water & urinal etc. for Student and staff. It is concluded that the sanitary conditions of the School are satisfactory. This NOC is Valid from 16/06/2021. 17/06/2020 to


Dy. Civil Surgeon (Health)
Rohtak Rohtak


VIDYA SHREE INTERNATIONAL
SCHOOL


Principal
V.S.I.S., Rtk

Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Rohtak
Near 2nd Water Works, Jhajjar Road, Rohtak-124001

Email id: chemist.rohtak@gmail.com

Test Report

Lab.No.:CH-45/07/2020
Date of Report 13.07.2020

- | | |
|------------------------|---|
| 1. Sender's Address | Dr. Vikash Siwach
Vidya Shree International School
6 th Mile Stone, Sonipat Road, Rohtak |
| 2. Source of Sample | Water Sample of premises |
| 3. Collected on* | 09.07.2020 |
| 4. Received on | 10.07.2020 |
| 5. Ref No. | Nil |
| 6. Sample Collected by | Party itself |

Dated-09.07.2020


Sr. No	Substance/Characteristic	Result	Desirable Limit	Maximum Permissible Limit (in absence of better alternative source)
			As per IS:10500:2012 (Second Revision)	
1	Colour, Hazen Units		5	15
2	Odour		Agreeable	Agreeable
3	Taste		Agreeable	Agreeable
4	Turbidity, NTU		1	5
5	Total Dissolved Solids, mg/l	80	500	2000
6	Total Hardness, mg/l	40	200	600
7	Calcium (as Ca), mg/l	9.22	75	200
8	Magnesium (as Mg), mg/l	4.14	30	100
9	Alkalinity, mg/l	220	200	600
10	Chloride (as Cl), mg/l	28.36	250	1000
11	Sulphate (as SO ₄), mg/l	20	200	400
12	Fluoride (as F), mg/l	0.01	1.0	1.5
13	Iron (as Fe), mg/l	0.3	0.3	No relaxation
14	Nitrate (as NO ₃), mg/l	1.1	45	No relaxation
15	pH value	7.75	6.5-8.5	No relaxation


Bacteriological Test:-

Lab.No.	Name of the person who collected the samples	Date of Sample Collection	Source of Sample	The Probable coliform count per 100ml of water sample	Remark
Bact319/07/2020	Party self	09.07.2020	Water sample of Premises	nil	Potable

Remarks:-

- This report cannot be reproduced, without the permission of the department.
- The sample will be destroyed after the issue of test report.
- Reliability of the samples lies with the sender of the sample.
- The test report can not be used for any publicity or any legal purpose.


 (Ms. Deepika)
 Authorized Signatory/Chemist
 PHED Water Testing Laboratory, Rohtak


VIDYA SHREE INTERNATIONAL SCHOOL

Principal
V.S.I.S., Rtk

END OF TEST REPORT

To

Vidya Shree International School
6th Mile Stone, Sonipat Road
Rohtak


Memo No.- 369 Dated - 13/7/2020

Subject:- Report of Chemical and bacteriological test of water sample.


Reference:- Memo no. -Nil dated-09.07.2020

Please find enclosed herewith 1 No. analysis report of water sample of Vidya Shree International, 6th Mile Stone, Sonipat Road, Rohtak. received vide your letter under reference on dated 10.07. 2020 for information and further necessary action.


DA/As above



(Ms. Deepika)
Authorized Signatory/Chemist
PHED Water Testing Laboratory, Rohtak



VIDYA SHREE INTERNATIONAL
SCHOOL



Principal
V.S.I.S., Rtk